



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DV-7301BS0316

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Inoxidables de Rábade, S.A. Ctra. Outeiro-Castro Km 2.8, E-27150 Matela-Outeiro de Rei
Distributor <i>Vertreiber</i>	Inoxidables de Rábade, S.A. Ctra. Outeiro-Castro Km 2.8, E-27150 Matela-Outeiro de Rei
Product Category <i>Produktart</i>	stainless tubes: stainless steel tube (7301)
Product Description <i>Produktbezeichnung</i>	pipe made of stainless steel 1.4404
Model <i>Modell</i>	Edelstahlrohr "IRSA"
Test Reports <i>Prüfberichte</i>	laboratory control test: 120002818-16 from 01.12.2016 (MPM) type testing: 120002818 from 29.08.2007 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW GW 541 (01.10.2004)

Date of Expiry / File No. 29.08.2022 / 17-0517-WNV
Ablaufdatum / Aktenzeichen

09.10.2017 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Edelstahlrohr "IRSA"	manufacturing group: 15 up to 108	according to GW 541, table 3

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

tested diameters according to GW 541, table 3: 15,0 mm; 18,0 mm; 22,0 mm; 28,0 mm; 35,0 mm; 42,0 mm; 54,0 mm; 76,1 mm; 88,9 mm; 108 mm